



2331 Topaz Drive, Hatfield, PA 19440
TEL: 800-219-9095 • FAX: 800-219-9096

Certified Test Report

AUI002-16-05-17489-1



SOLD TO

AIRpipe USA
6855 S. Kyrene Road
Suite 101
Tempe, AZ 85283

SHIP TO

AIRpipe USA
6855 S. Kyrene Road
Suite 101
Tempe, AZ 85283
ATTN: Chadwick Hills

CUSTOMER P.O.

Verbal-Chad

CERTIFICATION DATE

5/24/2016

SHIP VIA

EMAIL OTHER

DESCRIPTION

Quantity: 7
Description: 1 pc. each:

20 mm Assembly;
25 mm Assembly;
40 mm Assembly;
50 mm Assembly;
63 mm Assembly;
80 mm Assembly;
100 mm Assembly

The above material was 100% Hydrostatically Pressure tested at 150 PSI, held for ten minutes in accordance with Customer's Instructions using L.T.I. Procedure HY-1, Rev. 5, dated 12/5/2014 and (7) pieces were found to be acceptable to those requirements.

The above material was 100% Hydrostatically Pressure tested at 250 PSI, held for ten minutes in accordance with Customer's Instructions using L.T.I. Procedure HY-1, Rev. 5, dated 12/5/2014 and (7) pieces were found to be acceptable to those requirements.

The above material was 100% Hydrostatically Pressure tested at 350 PSI, held for ten minutes in accordance with Customer's Instructions using L.T.I. Procedure HY-1, Rev. 5, dated 12/5/2014 and (7) pieces were found to be acceptable to those requirements.

The above material was 100% Hydrostatically Pressure tested at 450 PSI, held for ten minutes in accordance with Customer's Instructions using L.T.I. Procedure HY-1, Rev. 5, dated 12/5/2014 and (7) pieces were found to be acceptable to those requirements.

The services performed above were done in accordance with LTI's Quality System Program Manual Revision 20 dated 12/12/12 and ISO/IEC 17025. These results relate only to the items tested and this report shall not be reproduced, except in full, without the written approval of Laboratory Testing, Inc. L.T.I. is accredited by Nadcap for NDT and Materials Testing for the test methods and specific services as listed in the Scopes of Accreditation available at www.labtesting.com and www.eAuditNet.com. The results reported on this test report represent the actual attributes of the material tested and indicate full compliance with all applicable specification and contract requirements.

MERCURY CONTAMINATION: During the testing and inspection, the product did not come in direct contact with mercury or any of its compounds nor with any mercury containing devices employing a single boundary of containment.

NOTE: The recording of false, fictitious or fraudulent statements or entries on this document may be punishable as a felony under Federal Statutes.

Sherri L. Scheifele
QA Specialist

Authorized Signature